

CERTIFICATE OF COMPLIANCE

Certificate Number 20161208-R18515
Report Reference R18515-19980925
Issue Date 2016-DECEMBER-08

Issued to: DETEX CORPORATION
302 DETEX DR
NEW BRAUNFELS TX 78130

**This is to certify that
representative samples of**

FIRE EXIT HARDWARE

Fire exit hardware, Series F10 and F40 rim type devices for use on 3, 1-1/2 or 3/4 h single and double fire doors with F90KR, F90R and FH90R mullions. These devices may be suffixed with FC, ES, ER, EA, EB, EH, EI, ED, LD, EX, EE, EM, H, EX x W, ED x EX, ER x EX, EE x ER or W.


Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL/ 10C Standard for Positive Pressure Fire Tests of Door Assemblies
ANSI/UL/ 10B Standard for Fire Tests of Door Assemblies
CAN/ULC-S104 Standard Method for Fire Tests of Door Assemblies

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

